

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 8

Dated: 23/1/25

It is certified that an inspection team headed by **Mr. Manish Thackar** from **Incharge Chemist, Sub Division, PHED Indore (MP)** inspected the **Indore Public School, Village Badodiya Khan, Tehsil Sanwer, Dist. Indore (MP)** on 20/01/2025 and on the basis of Water Test Report bearing no CH/25/010 dated 23/01/2025 certified that the **Indore Public School** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 Year

*P. Sharma*  
**Mr. Praveen Sharma**  
**Assistant Engineer**  
Maint. Sub Dn. No. 8  
PHE, INDORE (M.P.)

To,

**Indore Public School**  
**Village Badodiya Khan,**  
**Tehsil Sanwer, Dist. Indore (MP)**

# Water Testing Laboratory

## Indore Municipal Corporation, Musakhedi, Indore


### Test Certificate

<b>Sample from :-</b> Indore Public School, <b>Village Badodiya Khan, Tehsil Sanwer,</b> <b>Indore</b> <b>Sample Details</b> 1ltr Bottle by your self	Report No:CH/25/010
	Date of Collection :20/01/25
	Date of Receipt : 20/01/25
	Completion date : 23/01/25
	Time of Receipt :

S.No.	Tests	Units	Desirable Limit IS-10500-12	Permissible Limit IS-10500-12	Results
<b>A.</b>	<b>Organoleptic and Physical Parameters</b>				
1.	Temperature	°C	----	----	
2.	Colour	Platinum Cobalt Scale	5	15	0
3.	Odour		Agreeable	Agreeable	Agreeable
4.	Turbidity	N.T.U.	1	5	0.09
5.	Total Dissolved Solids	mg/l	500	2000	64
<b>B.</b>	<b>General Parameters Concerning Substances Undesirable in Excessive Amounts</b>				
6	pH	pH scale	6.5-8.5	No Relaxation	7.44
7.	Alkalinity	mg/l	200	600	14
8.	Total Hardness	mg/l	300	600	23
9.	Chloride	mg/l	250	1000	10
10.	Fluoride	mg/l	1.0	1.5	0.1
11.	Iron	mg/l	0.3	1.0	BDL
12.	Calcium	mg/l	75	200	1.2
13.	Magnesium	mg/l	30	100	4.8
14.	Sulphate	mg/l	200	400	3
15.	Nitrate	mg/l	45	No Relaxation	1.5
<b>C.</b>	<b>Coliform Count</b>				
19.	Thermotolerant Coliform bacteria	CFU/100ml	0	0	0

'BDL ' Below determination limit

**Remark:-** Tested parameter confirms desirable limit hence safe for drinking.

  
**Technical Manager**  
**Water Testing Laboratory**  
**M. C. Musakhedi**  
**Authorized Signatory (TM)**  
**INDORE (M.P.)**